

# CERTIFICATE of Conformity



**Certificate No.:** MK 69241633 0001

**Test Report No.:** 28202201 004

**Certificate Holder:** Westprofil Holzprodukt-Vertriebs GmbH  
Spittaler Strasse, 29  
32584 Löhne  
Germany

**Manufacturer:** - -

**Product:**

Axial fans

**Identification:**

Type designation:

Rated power input:

|               |               |     |
|---------------|---------------|-----|
| Line 100 12 ; | Line 100 S 12 | 14W |
| Line 125 12 ; | Line 125 S 12 | 16W |
| Line 150 12   | Line 150 S 12 | 24W |

|                       |             |
|-----------------------|-------------|
| Trade mark:           | BLAUBERG    |
| Rated voltage:        | 12V, 50Hz   |
| Protection class:     | III         |
| Degree of protection: | IP34        |
| where S:              | with switch |

**Tested according to:** EN 60335-1:2002+A1+A11+A2+A12+A13+A14  
EN 60335-2-80:2003+A1+A2  
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**

Budapest, 2012.01.17



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Vac ut. 48/A-B — [www.tuv.hu](http://www.tuv.hu)  
IT\_07-D-Pe\_4\_0